

GOVERNMENT OF KARNATAKA

No: PHI/Water/BAC/ 372/2024-25

Office of the Joint Director
Public Health Institute
Bengaluru - 560 001

Dated: 4/05/2024

Report of Bacteriological analysis of Water/Effluent sample

medical officer UPHC N.S Patya Bangalore - 76	Opinion					S.P.P	N.S.P.P	N.P.PP & FC.
	Sample No.	Source & Particulars of Water Sample	M.P.N Count	Plate Count	D.C. TEST			
	907	Golden bee Global School N.S Patya R.O. Plant	Nil	-	-	SPP	-	-
<p>Note: M.P.N Count: Most Probable Number of Bacteria per 100ml of Water D.C Test: Differential Coliform test Plate Count: Plate Count per ml of sample S.P.P: Water is satisfactory for Potable purpose NSPP: Water is not satisfactory for Drinking purpose NSPP & FC: Water is not satisfactory for Drinking purpose and E.Coil found</p>								

For Joint Director (Labs)
PUBLIC HEALTH INSTITUTE
Bengaluru

(PTO)

Advice:

1. Sample.....

Need effective chlorination before use

2. Sample.....

Need to avoid possible source of faecal contamination and affective chlorination before use
For the purpose of chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WATER

		Presumptive Coliform count per 100ml	E coil count per 100 ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or More

GOVERNMENT OF KARNATAKA

No: PHI/Water/BAC/372/2024/25

Office of the Joint Director
Public Health Institute
Bengaluru - 560 001

Dated:4/05/2024

Report of Bacteriological analysis of Water/Effluent sample

Medical Officer UPHC N.S Palya Bangalore - 76	Opinion					S.P.P	N.S.P.P	N.P.PP & FC.
	Sample No.	Source & Particulars of Water Sample	M.P.N Count	Plate Count	D.C. TEST			
	907	Goldenbee Global School N.S Palya R.O Plant	Nil	-	-	SPP	-	-
<p>Note: M.P.N Count: Most Probable Number of Bacteria per 100ml of Water D.C Test: Differential Coliform test Plate Count: Plate Count per ml of sample S.P.P: Water is satisfactory for Potable purpose NSPP: Water is not satisfactory for Drinking purpose NSPP & FC: Water is not satisfactory for Drinking purpose and E.Coil found</p>								



TRUE COPY ATTESTED

Hegde
 Hegde Ganapati Venkatraman
 ADVOCATE & NOTARY PUBLIC
 GOVT. OF INDIA
 # 180, B. C. M. C. Layout, Raghuvanahalli,
 Kanakapura Road, BENGALURU - 560 062

For Joint Director (Labs)
 PUBLIC HEALTH INSTITUTE
 Bengaluru

(PTO)

07 SEP 2024

Advice: 1. Sample.....

Need effective chlorination before use

2. Sample.....

Need to avoid possible source of faecal contamination and affective chlorination before use
For the purpose of chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WATER

		Presumptive Coliform count per 100ml	E coil count per 100 ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or More

TRUE COPY ATTESTED

Hegde

Hegde Ganapati Venkatraman
ADVOCATE & NOTARY PUBLIC
GOVT. OF INDIA

180, B. C. M. C. Layout, Raghuvanahalli,
Kanakapura Road, BENGALURU - 560 062

U 2 SEP 2024

